



CERTIFICATE OF COMPLIANCE

**Colder Products-Northpark
1001 Westgate Drive
St. Paul, Minnesota 55114**

February 4, 2014

Clean Area Description	Clean Area Class	Clean Area Status
Northpark Gowning	ISO 7	Operational
Northpark Production	ISO 7	Operational
Northpark In	ISO 7	Operational
Northpark Out	ISO 7	Operational
Airlock	Not Certified	Operational

Per the results of the particle count testing, the class is considered met if the measured particle concentration is within the limits specified per ISO 14644-1 (1999). Particle counts were sampled and reported in the cumulative mode for sizes 0.5 μm , 1.0 μm , and 5.0 μm at a flow rate of 1 cubic foot per minute.

CSI Testing, Inc. certifies that the above referenced clean area has been tested and meets or exceeds the stated class conditions in accordance with ISO 14644-1 (1999). CSI Testing, Inc. makes no other warranties, stated or implied, concerning the continued performance, operation or safety in use of the clean spaces listed above.

Submitted and Certified by:

CSI Testing, Inc.